

DECLARATION

I declare that this dissertation entitle “Analysis of Voltage Stability Problems in Power System” is the result of my own research except as cited in the references. The dissertation has not been accepted for any degree and is not concurrently submitted in candidature of any other degree.

Signature :

Name : Noor Ropidah binti Bujal
.....

Date :

APPROVAL

I hereby declare that I have read this dissertation and in my opinion this dissertation is sufficient in terms of scope and quality as a partial fulfillment of Master of Electrical Engineering (Industrial Power).

Signature :

Supervisor Name : **Marizan bin Sulaiman**

Date :

DEDICATION

To my beloved daughter

Zara Sakina Binti Mohammad Zuhaidi

ABSTRACT

Voltage stability analysis is important in power system in order to maintain the power system equilibrium. This research focuses on the voltage stability analysis of the power system feeders at distribution and transmission systems. The voltage stability analysis is carried out on the basis of single feeder comprising of two-bus system using ABCD line parameters. The feeder's voltage in distribution and transmission system has been monitored at lagging and leading load conditions for various power factors. Hence, the active power-voltage (P-V) curve and reactive power-voltage (Q-V) are used as tools to monitor the voltage stability at feeders. The plotting methods for PV and QV curves have been improved by using MATLAB applications software. The voltage critical, voltage regulation, voltage gap and line current are monitored at each load power factor. The results of P-V and Q-V curves show very high accuracy for both lagging and leading load condition and these results agree with previous research outputs. The voltage stability analysis incorporates the Graphical User Interface (GUI) for user friendly suitable for teaching, learning and training application. The GUI is implemented using MATLAB GUI and this software package is targeted for engineering students and practicing engineers.

ABSTRAK

Analisis kestabilan voltan adalah sangat penting dalam sistem kuasa untuk memastikan sistem kekal berada dalam keseimbangan. Fokus kajian ini adalah dalam menganalisa kestabilan voltan di setiap penyuar voltan dalam sistem kuasa khususnya dalam sistem pengagihan dan sistem penghantaran kuasa. Analisis kestabilan voltan ini dijalankan ke atas sistem dua-bas dengan menggunakan parameter talian ABCD. Voltan di setiap penyuar voltan dalam sistem pengagihan dan penghantaran kuasa dipantau bagi beban yang mengekor dan beban yang mendahului untuk pelbagai faktor kuasa. Oleh itu, graf lengkung kuasa sebenar-voltan ($P-V$) and graf lengkung kuasa reaktif – voltan ($Q-V$) digunakan sebagai alat untuk memantau kestabilan voltan di penyuar voltan. Kaedah memplot graf lengkung $P-V$ dan $Q-V$ juga ditambah baik dengan menggunakan perisian aplikasi MATLAB. Jumlah voltan kritikal, peratus pengaturan voltan, jurang voltan dan arus talian dipantau pada setiap faktor kuasa beban. Graf lengkung $P-V$ dan $Q-V$ yang diperolehi menunjukkan ketepatan yang tinggi untuk kedua-dua keadaan beban mengekor dan mendahului dan keputusan ini bertepatan dengan hasil penyelidikan sebelumnya. Analisa kestabilan voltan ini juga digabungkan dengan satu antaramuka grafik pengguna untuk tujuan pengajaran, pembelajaran serta latihan. Antaramuka pengguna juga dibangunkan menggunakan perisian MATLAB GUI dan pakej perisian ini disasarkan untuk pelajar-pelajar kejuruteraan dan jurutera–jurutera pelatih.

ACKNOWLEDGMENTS

Alhamdulillah, all praises to Allah for everything. First and foremost, I would like to express my sincere appreciation to my supervisor, Engr. Prof. Dr. Marizan bin Sulaiman for his supervision and endless support. His guidance and advices helped me in completing this dissertation. I could not have imagined having a better supervisor for my study.

Special thanks to Universiti Teknikal Malaysia Melaka (UTeM) for giving me the opportunity to pursue Master of Electrical Engineering (Industrial Power) here. It just like a dream comes true.

I also want to express my warm thanks to my colleagues who supported me in this dissertation for all their help, support, interest and valuable hints. Sincere thanks to all my fellow friends in UTeM for the help, friendship and sweet memories.

Last but not least, my deepest gratitude goes to my beloved husband Mohammad Zuhaidi Mohd Noor and my daughter Zara Sakina Mohammad Zuhaidi for their endless love, prayers, supports, sacrifices and encouragement. Thank you very much once again to every single person who directly or indirectly contributed to this research.

TABLE OF CONTENTS

	PAGE
DECLARATION	
APPROVAL	
DEDICATION	
ABSTRACT	i
ABSTRAK	ii
ACKNOWLEDGMENTS	iii
TABLE OF CONTENTS	iv
LIST OF TABLES	vi
LIST OF FIGURES	viii
LIST OF APPENDICES	xi
LIST OF ABBREVIATIONS	xii
LIST OF SYMBOLS	xiii
LIST OF PUBLICATIONS	xv
CHAPTER	
1. INTRODUCTION	1
1.1 Background	1
1.2 Motivation of Research	2
1.3 Problem Statement	2
1.4 Research Objective	3
1.5 Contribution of Research	3
1.6 Scope of Research	4
1.7 Organization of Dissertation	4
2. LITERATURE REVIEW AND THEORETICAL BACKGROUND	6
2.1 Introduction	6
2.2 Literature Review	6
2.2.1 Voltage Stability	10
2.2.2 Voltage Instability	10
2.2.3 Voltage Collapse	11
2.2.4 P-V Curves and Q-V Curves	13
2.3 Transmission Line	15
2.3.1 Short-Length Transmission Line	18
2.3.2 Medium-Length Transmission Line	21
2.4 Types of Loads	24
2.4.1 Pure Resistive Load	24
2.4.2 Pure Inductive Load	25
2.4.3 Pure Capacitive Load	27
2.4.4 Typical Load	28
2.5 Power factor	30
2.6 Voltage Regulation	31
2.6.1 Voltage Drop	36
2.6.2 Transmission Line Efficiency	37
2.7 Voltage Gap	38
2.8 Summary	39

3. SYSTEM DESIGN AND DEVELOPMENT	40
3.1 Introduction	40
3.2 Voltage Stability Analysis using P-V and Q-V Curve	40
3.2.1 Case 1: Three-Phase Distribution System	43
3.2.2 Case 2: Three-Phase Transmission System	43
3.3 P-V and Q-V Algorithms	44
3.3.1 Part A: Calculation of Critical Point of P-V and Q-V Curves	44
3.3.2 Part B: Calculation of Other Points at P-V and Q-V curves.	47
3.3.3 Part C: Calculations of Receiving and Sending End Data, Voltage Regulation and Voltage Gap	48
3.3.4 Calculation of Three Phase Distribution System (Case 1)	51
3.3.4.1 P-V and Q-V Curves for Lagging Load Power Factor	52
3.3.4.2 P-V and Q-V Curves for Leading Power Factor	56
3.3.4.3 P-V and Q-V Curves for Unity Power Factor	61
3.3.5 Calculation of Three Phase Transmission System (Case 2)	65
3.3.5.1 P-V and Q-V Curves for Lagging Load Power Factor	65
3.3.5.2 P-V and Q-V Curves for Leading Power Factor	69
3.3.5.3 P-V and Q-V Curves for Unity Power Factor	73
3.4 Graphical User Interface (GUI) Development	78
3.4.1 Designed GUI Page	81
3.4.2 Types of Transmission Line Panel	82
3.4.3 Power Factor Panel	82
3.4.4 Load Condition Panel	83
3.4.5 Line Parameters Panel	84
3.4.6 Action Menu Panel	84
3.4.7 Data Panel	86
3.4.8 Curve Panel	87
3.4.9 Curve Data Panel	89
3.4.10 Critical Point Panel	89
3.5 Summary	90
4. DISCUSSION OF RESULTS	91
4.1 Introduction	91
4.2 Short-Length Transmission Line (Distribution System)	91
4.2.1 Results of Short-Length Transmission Line at Lagging, Leading and Unity Power Factor	92
4.3 Medium-Length Transmission Line	104
4.3.1 Result of Medium Transmission Line at Lagging, Leading and Unity Power Factor	104
4.4 Summary	115
5. CONCLUSION	116
5.1 Introduction	116
5.2 Summary of Research Work	116
5.3 Attainment of Research Objective	119
5.4 Significance of Research Outputs	119
5.5 Suggestion for Future Work	120
REFERENCES	121
APPENDICES	128

LIST OF TABLES

TABLE	TITLE	PAGE
2.1	Typical Secondary Voltage Standards Applicable to Residential and Commercial Customer	34
2.2	Steady-state Voltage Level Fluctuation Limits Under Normal Condition	35
2.3	Steady-state Voltage Level Fluctuation Limits Under Contingency Condition	35
3.1	Calculation of Part B (Lagging Load Power Factor)	54
3.2	Calculations of Part B (Leading Load Power Factor)	59
3.3	Calculations of Part B (Unity Power Factor)	63
3.4	Calculations of Part B (Lagging Load Power Factor)	67
3.5	Calculations of Part B (Leading Load Power Factor)	71
3.6	Calculations of Part B (Unity Power Factor)	76
3.7	Function of Button at Action Menu Panel	85
3.8	Shortcut Key for Action Menu Panel	86
4.1	Data at the Critical Point for Short-Length Transmission Line	92
	(a) Data of Critical Point at 0.707 Power Factor	92
	(b) Data of Critical Point at 0.8 Power Factor	92
	(c) Data of Critical Point at 0.85 Power Factor	93
	(d) Data of Critical Point at 0.9 Power Factor	93

	(e)	Data of Critical Point at 0.95 Power Factor	93
	(f)	Data of Critical Point at Unity Power Factor	93
4.2		Data at P-V and Q-V Curve Critical Point of Medium Transmission Line	105
	(a)	Data of Critical Point at 0.707 Power Factor	105
	(b)	Data of Critical Point at 0.8 Power Factor	105
	(c)	Data of Critical Point at 0.85 Power Factor	106
	(d)	Data of Critical Point at 0.9 Power Factor	106
	(e)	Data of Critical Point at 0.95 Power Factor	106
	(f)	Data of Critical Point at Unity Power Factor	106

LIST OF FIGURES

FIGURE	TITLE	PAGE
2.1	Nose Curves as Parameter: (1) $\varphi = 45^\circ$ lag; (2) $\varphi = 30^\circ$ lag; $\varphi = 0$; (4) $\varphi = 30^\circ$ lead	9
2.2	P-V Curve for Different Load Power Factors	13
2.3	V-Q Curve for Different Load Power Factors	14
2.4	Radial Transmission Line	15
2.5	Two-port Network Representation of Transmission Line	16
2.6	Short-Length Transmission Line Equivalent Circuit	18
2.7	Symbolic Representation of a Line	19
2.8	Medium-Length Transmission Line Equivalent Circuit	22
2.9	Pure Resistive Load Phasor Diagram	25
2.10	Medium-Length Transmission Line with Resistive Load	25
2.11	Pure Inductive Load Phasor Diagram	26
2.12	Medium-length Transmission Line with Resistive and Inductive Load	26
2.13	Pure Capacitive Load Phasor Diagram	27
2.14	Medium TL with Resistive and Capacitive Load	27
2.15	Short-Length Transmission Line with Inductive Load	28
2.16	Inductive Load with Lagging Power Factor	28
2.17	Short-Length Transmission Line with Capacitive Load	29

2.18	Capacitive Load with Leading Power Factor	29
2.19	Phasor Diagram for a Typical Distribution Load	30
2.20	Illustration of Voltage Regulation by Zone	34
2.21	Short-Length Transmission Line	36
2.22	Voltage Gap	38
3.1	P-V and Q-V Curves for Lagging Load Condition	42
3.2	P-V and Q-V Curves for Leading Load Condition	42
3.3	Flowchart of Critical Point of P-V and Q-V Curve Determination (Part A)	46
3.4	The Calculation Flow of Other Points at P-V and Q-V Curves (Part B)	47
3.5	Flowchart of Calculations (Part C)	49
3.6	Procedure in Using the GUI	80
3.7	GUI Page	81
3.8	Types of Transmission Line Panel	82
3.9	Power Factor Angle Panel	83
3.10	Load Condition Panel	83
3.11	Line Parameters Panel	84
3.12	Action Menu Panel	85
3.13	Data Panel	87
3.14	Curve Panel	88
3.15	Graph Legend	88
3.16	Curve Data Panel	89
3.17	Critical Point Panel	89
4.1	P-V and Q-V Curve at 0.707 Lagging (Bad Power Factor)	95

4.2	P-V and Q-V Curve at 0.8 Lagging (Good Power Factor)	96
4.3	P-V and Q-V Curve at 0.9 Lagging (Good Power Factor)	97
4.4	P-V and Q-V Curve at 0.707 Leading (Bad Power Factor)	98
4.5	P-V and Q-V curve at 0.8 Leading (Good Power Factor)	99
4.6	P-V and Q-V Curve at 0.9 Leading Power Factor (Very Good Power factor)	100
4.7	P-V and Q-V Curve for Bad (0.707) and Very Good (0.95) Lagging Power Factor	101
4.8	P-V and Q-V Curve for Bad (0.707) and Very Good (0.95) Leading Power Factor	102
4.9	P-V and Q-V Curve for Short Transmission Line at Unity Power Factor	103
4.10	P-V and Q-V Curve at 0.707 Lagging (Bad Power Factor)	107
4.11	P-V and Q-V Curve at 0.85 Lag (Good Power Factor)	108
4.12	P-V and Q-V Curve at 0.95 Lag (Very Good Power Factor)	108
4.13	P-V and Q-V Curve at 0.707 Leading (Bad Power Factor)	109
4.14	P-V and Q-V Curve at 0.85 Leading (Good Power Factor)	110
4.15	P-V and Q-V Curve at 0.95 Leading (Very Good Power Factor)	111
4.16	P-V and Q-V Curve for Medium Transmission Line At Unity Power Factor	112

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	Simulation Results of Short-length Transmission Line at Lagging Load Condition and Unity Power Factor	129
B	Simulation Results of Short-length Transmission Line at Leading Load Condition	141
C	Simulation Results of Medium-length Transmission Line at Lagging Load Condition and Unity Power Factor	151
D	Simulation Results of Medium-length Transmission Line at Leading Load Condition	163

LIST OF ABBREVIATIONS

AC	-	Alternating current
C	-	Capacitance
FACT	-	Flexible AC transmission
GUI	-	Graphical user interface
IEEE	-	Institute of Electrical and Electronics Engineers
KCL	-	Kirchhoff Current law
kV	-	Kilo volt
LTC	-	Load tap changing
MATLAB	-	Math lab works
MVA	-	Mega Volt ampere
MW	-	Mega watt
P-V	-	Power to voltage
Q-V	-	Reactive power to voltage
R	-	Resistance
STATCOM	-	Static synchronous compensators
SVC	-	Static VAR compensators
TNB	-	Tenaga Nasional Berhad
VAR	-	Volt ampere reactive

LIST OF SYMBOLS

ω	-	Angular frequency
$^{\circ}$	-	Degree
π	-	Pi
E_{Rcr}	-	Critical voltage
I_c	-	Capacitor Current
I_R	-	Receiving-end current
I_S	-	Sending-end current
L	-	Inductance
l	-	Line length
P	-	Real power
p.f	-	Power Factor,
P_R	-	Receiving-end real/ active power
P_R	-	Receiving-end active power
P_{Rmax}	-	Maximum receiving-end active power
Q	-	Reactive power
Q_R	-	Receiving-end reactive power
Q_{Rmax}	-	Maximum receiving-end reactive power
r	-	Per-phase resistance
S	-	Apparent Power/ Complex Power
V_{cr}	-	Voltage Critical

V_{gap}	-	Voltage gap
V_R	-	Receiving-end voltage
V_{rated}	-	Rated Voltage
V_{Rcr}	-	Critical Receiving End Voltage
V_{reg}	-	Voltage regulation
V_{RFL}	-	Full-load receiving end
V_{RNL}	-	No-load receiving end
V_S	-	Sending End Voltage, and
Y	-	Admittance
Z	-	Series impedance
δ'	-	Delta prime
δ'_{cr}	-	Prime critical angle
δ_{cr}	-	Delta Critical
η	-	Efficiency
θ	-	Theta
ϕ	-	Phi (Power factor angle)
ϕ'	-	Phi Prime

LIST OF PUBLICATIONS

- [1] Analysis of Voltage Stability Problems in Power System. Accepted for presentation in International Conference “Engineering- *Technology & Technopreneurship*” on 27-29 August 2014.

- [2] A Graphical User Interface (GUI) for Voltage Stability Analysis. Accepted for presentation in National Conference “*Conference in Education-Technical Vocational Education and Training*” on 26 August 2014.

CHAPTER 1

INTRODUCTION

1.1 Background

Power system stability is an ability of electric power system to regain a state of operating equilibrium after being subjected to a disturbance (Dorf, 2007). There are three classes of power system stability, namely rotor angle stability, frequency stability and voltage stability (Dorf, 2007). Voltage stability is in respect of the ability of a power system to maintain steady voltage at all busses in the system under normal condition and after being subjected to a disturbance (Kundur, 2004). However, voltage instability may occur either when voltage fall or rises at some busses. Therefore, the voltage stability analysis should be implemented to monitor the voltage stability at voltage feeder and improves the power system stability.

The quantity of power transmitted is based on power factor and ABCD line parameters. The load condition at transmission feeder will affect the transmission line performance in terms of voltage critical, voltage drop, voltage regulation and transmission line current. P-V curve and Q-V curve are widely used to monitor the voltage stability of distribution and transmission feeder (Khan, 2007). Therefore, in this study, P-V and Q-V curve for various power factors are used as a tool for analyzing voltage stability.

1.2 Motivation of Research

The research has been done with the fact that voltage at each feeder system plays a significant role in power system. Therefore the voltage should be monitored to avoid the power system failure. This research focuses on voltage stability by monitoring real power demand (P), reactive power (Q) and receiving end voltage (V_R) at the feeder of the transmission system and distribution system compared to previous researches that study one of the curves and separately.

The P-V curve and Q-V curve are simple methods to use as tools to monitor the voltage and power because it can represent the whole system performance with single graph. Besides, voltage regulation and voltage gap for different lagging and leading load conditions are also associated with the voltage stability. The P-V and Q-V plotting method need to be improved with more points or interval to ensure the accuracy of the analysis.

1.3 Problem Statement

In power system, a bulk of power is transmitted to load through a transmission and distribution line. There are loads that operate at either lagging or leading power factor. Each type of load will give different effects to the transmission and distribution feeder and may cause voltage stability problems.

The load conditions also affect the performance of both system feeder in terms of voltage regulation, voltage gap and line current. Therefore, the voltage at a different feeder of transmission and distribution systems should be calculated and monitored by using P-V and Q-V curve. The curves show the variation of both power demands (P and Q) with respect to the terminal voltage of the receiving-end feeders for loads operating at either lagging or leading condition of power factors. However, previous curves plotting need a complex calculation for each load conditions. The curves also were plotted using a few

points which not ensure the accuracy of results analysis. Besides, only P-V curves mostly used in voltage stability monitoring. The P-V and Q-V curves tracing method also need to be improved due to the complexity of calculation involved in analysis.

1.4 Research Objective

The objectives of this research are:

- i. The Graphical User Interface (GUI) based software using MATLAB that has an ability to analyze Voltage Stability in Short and Medium-length transmission lines.
- ii. To improve plotting method for P-V and Q-V curve for short and medium-length transmission lines by using more points based on critical angle for analysis's accuracy and using programming incorporate with GUI and display the curves based on any power factor that enter by user.
- iii. To determine the voltage regulation within the acceptable region of short-length and medium-length transmission line, operating voltage, critical voltage, voltage gap and line current for different operation load conditions.

1.5 Contribution of Research

The contributions of this research include:

- i. Improve tracing method for P-V and Q-V curves for short-length and medium-length transmission lines by using more points based on critical angle for analysis's accuracy and using programming incorporate with GUI and display the curves based on any power factor that enter by user. All the curve and data can be saved and retrieve at any time.

- ii. Calculations of voltage regulation, line current and voltage gap for lagging and leading load power factors for both P-V and Q-V curves to show the positive Q absorption for lagging and negative Q generation for leading.
- iii. The GUI based P-V and Q-V curves can be used for teaching, learning and training package.

1.6 Scope of Research

The scope of this research covers the followings:

- i. The voltage stability analysis for short-length and medium-length transmission line only.
- ii. The P-V curve and Q-V curve are plotted to monitor voltage at the transmission line feeder.
- iii. The voltage regulation, line current and voltage gap are calculated to monitor the lines performance.

1.7 Organization of Dissertation

This dissertation is divided into five chapters. Chapter 1 introduces about the research background, research motivation, problem statement, research objectives and scope of research. Chapter 2 will focus on the related literature review and theoretical background of the research. Basic theory of both short-length and medium-length transmission line are discussed in this chapter.

Chapter 3 concentrates on the system design and development process. Algorithms that are used and all calculations are presented in this chapter. The development of the software for designing the analysis system and GUI development will also be discussed. Chapter 4 is a discussion of the results that are obtained from the simulation carried out.

The simulation results then were analyzed to identify the acceptable power factor for the short-length and medium-length transmission line for different lagging and leading power factors of load conditions. The discussion also includes the importance of P-V and Q-V curves at each feeder and the effect of lagging and leading load power factors variation at line feeder. Chapter 5 is a conclusion that summarizes all the research work that has been done. The suggestion for further research will be also highlighted at the end of the chapter.

CHAPTER 2

LITERITURE REVIEW AND THEORETICAL BACKGROUND

2.1 Introduction

This chapter will discuss mainly on the literature review and theoretical background of voltage stability analysis, active power to voltage (P-V) and reactive power to voltage (Q-V) curve, voltage regulation, line efficiency and voltage gap.

2.2 Literature Review

According to Zang et al. (2010), the techniques to perform voltage stability analysis fall into two categories which are static and dynamic. Static Voltage stability analysis has been chosen to recognize the weak area in terms of reactive power insufficiency and unforeseen event in the system. From that, the voltage stability margin for different power transfers can be obtained within the system. This paper also agrees that power-voltage curves and reactive-voltage curve are commonly used to determine system weakness, weak point, margin of instability and voltage collapse. A tool was built up using programming language Python for shortage screening and P-V analysis. Furthermore, this literature focuses on the determination of the voltage instability region in order to recognize voltage collapse area through P-V and Q-V curve by using Phyton tools.

Vargas et al. (2009) state that P-V curves normally used to assess the operating condition of the power system. P-V curves are graphic indicator to show how the voltage on the load bus varies according to real power, P flows to Load."Nose" of the curve shows the maximum power transfer and also known as the critical point. The curve is a plot based